

WARMTE-AFGIFTE VLOER-WANDVERWARMING VOOR HET KLIMAATSYSTEEM
H.o.h. afstand 100 mm
VLOERVERWARMING KLIMAATSYSTEEM

		T-ruimte				
		15°C	18°C	20°C	22°C	24°C
t water gem	47,5°C	183	165	154	143	132
	45°C	168	152	140	129	117
	42,5°C	153	137	126	114	102
	40°C	138	122	110	99	88
	37,5°C	124	108	97	85	74
	35°C	109	93	83	70	60
	32,5°C	95	79	68	57	47
	30°C	82	65	53	43	32
	27,5°C	67	51	40	29	18
	25°C	53	38	27	16	-

Waarden in Watt/m²
R=0,00 m² kW (bijv. tegels)

		T-ruimte				
		15°C	18°C	20°C	22°C	24°C
	45°C	125	112	104	95	87
	40°C	104	91	83	75	66
	35°C	83	70	62	54	45
	30°C	62	49	41	33	24

Waarden in Watt/m²
R=0,05 m² kW (bijv. parket kunststofvloer)

		T-ruimte				
		15°C	18°C	20°C	22°C	24°C
	45°C	99	89	82	75	69
	40°C	82	72	66	59	52
	35°C	66	56	49	42	36
	30°C	49	39	33	26	20

Waarden in Watt/m²
R=0,10 m² kW (bijv. parket kunststofvloer)
WANDVERWARMING KLIMAATSYSTEEM
H.o.h. afstand 75 mm

		T-ruimte				
		15°C	18°C	20°C	22°C	24°C
t water gem	25°C	90	59	38	18	0
	30°C	127	95	74	55	36
	35°C	162	131	111	91	73
	40°C	197	167	147	126	109
	45°C	232	201	181	161	143

Waarden in Watt/m²